

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1060670

Product: Impulse relay

Type: IR 116

Rating: Coil 230 V AC, Contacts 230 V AC/16 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 602511-01/01 of: 08.08.2006

A sample of the product was found to be in conformity with:
ČSN EN 61811-1:00, ČSN EN 61000-6-3:02+A11:05,
ČSN EN 55022:99+A1:01+A2:03+1:01+2:03+3:05+4:05, ČSN EN 61000-6-1:02

The validity of the certificate is limited to: 31.8.2009

9.8.2006

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



602511-01