

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHEQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1080409

**Product:** Circuit breaker MINIA

**Type:** LPN

**Rating:** 0,2; 0,4; 0,6; 0,8; 1; 1,2; 1,6; 2; 4; 6; 8; 10; 13; 16; 20; 25; 32; 40; 50; 63 A (1p); 0,2; 0,5; 0,6; 0,8; 1; 1,2; 1,6; 2; 4; 6; 8; 10; 13; 16; 20; 25; 32; 40; 50; 63 A (3p); AC 230/400 V, char.: B, C, D, 10 kA

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 800910-01/01 of: 15.04.2008

A sample of the product was found to be in conformity with:  
ČSN EN 60898-1:03+A1:05+1:05+A11:06

The validity of the certificate is limited to: 30.4.2011

22.4.2008

Prague

Pavel Kudrna  
Certification and Inspection Manager



Stamp



800910-01