

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080538

Product: Low-voltage surge protective devices

Type: SJB pro 35, SVD 250M

Rating: Uc=AC 260/440 V, 50/60 Hz, Iimp=35 kA(10/350) - type SJB pro 35
Uc= AC 250 V, 50/60 Hz, Isn=2,5 kA(8/20) - type SVD 250 M

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 801342-01/01 of: 06.05.2008

A sample of the product was found to be in conformity with:
ČSN EN 61643-11:03+A11:07

The validity of the certificate is limited to: 31.5.2011

3.6.2008

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



801342-01