

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1090868

Product: Surge protective devices

Type: SJBC-25E-3-MZS, SJBC-25E-3N-MZS

Rating: Uc: 264/350 V AC, Up: 1,5 kV, In: 25/100 kA, Iimp: 25/100 kA

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 903507-01/01 of: 30.09.2009

A sample of the product was found to be in conformity with:
ČSN EN 61643-11:03+A11:07

The validity of the certificate is limited to: 31.10.2012

21.10.2009

Prague

V. Z. Sedláček

Miroslav Sedláček
Certification and Inspection Manager



Stamp



903507-01