

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1100233

**Product:** In-line fuse-disconnector

**Type:** FH 000-1, FH 000-3

**Rating:** 160 A, 690 V AC

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 001057-01/01 of: 22.03.2010

A sample of the product was found to be in conformity with:

ČSN EN 60947-3:00 ed. 2+A1:02+A2:06+Z1:2010 cl. 5.2, 8.2, 8.3.3, 8.3.4, 8.3.6, 8.3.7,  
ČSN EN 60947-3:2010 ed. 3, ČSN EN 60947-1:08 ed.4, ČSN EN 60947-1:05 ed. 3+Z1:08 cl. 7.1.1, 7.1.1.1

The validity of the certificate is limited to: 31.3.2013

2.4.2010

Prague

Miroslav Sedláček  
Certification and Inspection Manager



Stamp



001057-01