

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1100234

**Product:** Fuse-disconnector

**Type:** FH1-1A, FH1-3A, FH2-1A, FH2-3A, FH3-1A, FH3-3A - see enclosure

**Rating:** AC 690 V, 250 A, 400 A, 630 A

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 001058-01/01 of: 23.03.2010

A sample of the product was found to be in conformity with:  
ČSN EN 60947-3:010 ed. 3 cl. 8.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6, 8.3.7, 5.2, 5.2.2, 5.2.3, 5.2.4, 7.1.4,  
ČSN EN 60947-1:08 ed. 4 cl. 7.1.2.2

The validity of the certificate is limited to: 31.3.2013

2.4.2010

Prague

Miroslav Sedláček  
Certification and Inspection Manager



Stamp



001058-01

Variants:

FH1-1A/F  
FH1-1S/F

FH1-3A/F  
FH1-3S/F

FH2-1A/F  
FH2-1S/F

FH2-3A/F  
FH2-3S/F

FH3-1A/F  
FH3-1S/F

FH3-3A/F  
FH3-3S/F

*Ukládě*

