

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1130216

Product: Circuit breaker

Type: BH100N (release SE-BH-0100-MTV9)

Rating: AC 690 V, 40-100 A, Uimp = 8 kV

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 301256-01/01 of 26.03.2013

A sample of the product was found to be in conformity with:
ČSN EN 60947-1 ed. 4:08+A1:2011 cl. 7.1.2.2, ČSN EN 60947-2 ed. 3:07+1:07+A1:2010 cl. 5.2, 7.1.3, 8.3.3-8.3.6,
tests according to enclosure C, F, G, H (seismic resistance 3g, 5-50 Hz)

The validity of the certificate is limited to: 31.3.2016

29.3.2013

Prague


Miroslav Sedláček
Head of Certification Body



Stamp



301256-01