

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1130494

**Product:** Empty enclosure for switchgear assemblies

**Type:** DZ43, DZ54 and accessories; DN43, DN54 and accessories

**Rating:** to 1000 V, to 400 A, to 36 kA, to IP 54

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** B a K production s. r. o.  
Purkratice 18, 397 01 Písek, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 302565-01/01 of: 10.06.2013

**A sample of the product was found to be in conformity with:**  
ČSN EN 62208 ed. 2:12

**The validity of the certificate is limited to:** 30.6.2016

25.6.2013

Prague

Jarmil Mikulík  
Deputy Head of Certification Body



Stamp



302565-01