

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1140351

Product: Circuit breaker

Type: BL1000S

Rating:  $U_e = 690$  V,  $I_u = 1000$  A, 50/60 Hz,  $I_{cs} = 20$  kA

Ordering firm: OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 400657-01/01 of: 28.04.2014

A sample of the product was found to be in conformity with:  
ČSN EN 60947-1 ed.4:08+A1:11, ČSN EN 60947-2 ed.3:07+1:07+A1:10+A2:13

The validity of the certificate is limited to: 30.4.2017

28.4.2014

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



400657-01