

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140353

Product: Circuit breakers

Type: BH 630N, BH 630S (plug-in and withdrawable construction)

Rating: $U_e = 690$ V, $I_u = 630$ A, 50/60 Hz, $I_{cs} = 8$ kA

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 400660-01/01 of: 28.04.2014

A sample of the product was found to be in conformity with:
ČSN EN 60947-1 ed.4:08+A1:11, ČSN EN 60947-2 ed.3:07+1:07+A1:10+A2:13

The validity of the certificate is limited to: 30.4.2017

28.4.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



400660-01