

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140704

Product: Fuse-base, Neutral terminal bridge

Type: SPF 00, 1, 2, 3, SNF 00, 1, 2

Rating: 690 V AC, 160, 250, 400, 630 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 100107-01/01 of: 04.08.2011

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed.3:08+A1:10

The validity of the certificate is limited to: 31.8.2017

11.8.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



403389-01