

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140710

Product: Fuse switch-disconnectors

Type: FSD 00,1,2,3

Rating: 160 A, 250 A, 400 A, 630 A; 690 V AC

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 403385-01/01 of: 12.08.2014

A sample of the product was found to be in conformity with:
ČSN EN 60947-3 ed.3:10+A1:12, ČSN EN 60947-1 ed.4:08+A1:11

The validity of the certificate is limited to: 31.8.2017

13.8.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



403385-01