

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1140724

**Product:** Cylindrical fuse for photovoltaic energy systems

**Type:** PC10gPV

**Rating:** Un 1000 V DC, In 2, 4, 6, 8, 10, 12, 16, 20 A

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 403387-01/01 of: 13.08.2014

A sample of the product was found to be in conformity with:  
ČSN EN 60269-6:11, ČSN EN 60269-1 ed.3:08+A1:10, ČSN 35 4701-2 ed.2:11

The validity of the certificate is limited to: 31.8.2017

21.8.2014

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



403387-01