

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140725

Product: Fuse rails

Type: FSR 00,1,2,3

Rating: 160 A, 250 A, 400 A, 630 A; 690 V AC

Ordering firm: O EZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: O EZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 403388-01/01 of: 14.08.2014

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed.3:08+A1:10, ČSN 35 4701-2 ed.2:11

The validity of the certificate is limited to: 31.8.2017

21.8.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



403388-01