

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1140839

**Product:** Fuse-disconnector

**Type:** OPVP10, 14, 22

**Rating:** 32 A, 50 A, 100 A; 690 V AC, 440 V DC

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 403929-01/01 of: 30.09.2014

**A sample of the product was found to be in conformity with:**  
ČSN EN 60947-3 ed. 3:10+A1:12, ČSN EN 60947-1 ed.4:08+A1:11

**The validity of the certificate is limited to:** 31.10.2017

7.10.2014

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



403929-01