

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140893

Product: Switch-disconnector

Type: MSO

Rating: 32-63 A, 80-125 A; 250/440 V; 1-4 pole

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Factories: Siemens Circuit Protection Systems Ltd.
Shanghai, China

Trade mark:

The test results are stated in the test-report No.: 403671-01/01 of: 17.10.2014

A sample of the product was found to be in conformity with:
ČSN EN 60947-3 ed.3:10+A1:12

The validity of the certificate is limited to: 31.10.2017

20.10.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



403671-01