

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140926

Product: Switch module

Type: MSK

Rating: AC 250 V, 6 A, 10 A, 16 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 403982-01/01 of: 29.10.2014

A sample of the product was found to be in conformity with:

ČSN EN 60947-5-1 ed.2:05+A1:10 cl. 4.3, 4.4, 5.2, 7.1.1 to 7.1.4, 7.1.7, 7.1.11, 8.3.3.3, 8.3.3.4;
ČSN EN 60947-1 ed.4:08+A1:11 cl. 8.2.4.2 to 8.2.4.4.;

The validity of the certificate is limited to: 31.10.2017

30.10.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



403982-01