

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1141001

**Product:** Plastic empty enclosures

**Type:** RNG, RZG, RZV

**Rating:** IP40, IK07, 520 V AC, class II, indoor application

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 405146-01/01 of: 19.11.2014

**A sample of the product was found to be in conformity with:**  
ČSN EN 62208 ed.2:12

**The validity of the certificate is limited to:** 30.11.2017

26.11.2014

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



405146-01