

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1141070

Product: Residual current operated circuit-breaker

Type: LFN, LFE (variants see enclosure)

Rating: 230 V AC, 400 V AC, 16 - 80 A, 0,01 A - 0,5 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 404921-01/01 of: 27.11.2014

A sample of the product was found to be in conformity with:
ČSN EN 61008-1 ed.3:13, ČSN EN 61008-2-1:97+A11:99

The validity of the certificate is limited to: 31.12.2017

15.12.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



404921-01

LFN;LFE residual current operated circuit-breaker

LFN-16-2-010A
LFN-25-2-030A
LFN-40-2-030A
LFN-25-4-030A
LFN-40-4-030A
LFN-63-4-030A
LFE-25-2-030AC
LFE-40-2-030AC
LFE-25-4-030AC
LFE-25-4-0300AC
LFE-40-4-030AC
LFE-40-4-0300AC
LFE-63-4-030AC
LFE-63-4-0300AC
LFE-16-2-010AC
LFN-25-2-030AC
LFN-25-2-0300AC
LFN-40-2-030AC
LFN-25-4-030AC
LFN-25-4-100AC
LFN-25-4-0300AC
LFN-40-4-030AC
LFN-40-4-100AC
LFN-40-4-300AC
LFN-63-4-030AC
LFN-63-4-100AC
LFN-63-4-300AC
LFN-80-4-030AC
LFN-80-4-300AC

