

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1141072

Product: Circuit-breaker

Type: LTN-UC (variants see enclosure)

Rating: 230/400 V AC, 400 V AC, 220 V DC, 440 V DC, 0,3 - 63 A, 1, 2 poles

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 404923-01/01 of: 27.11.2014

A sample of the product was found to be in conformity with:
ČSN EN 60898-1:03, ČSN EN 60898-2 ed. 2:07

The validity of the certificate is limited to: 31.12.2017

15.12.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



404923-01

LTN-UC Circuit-breaker

- LTN-UC-1C-1
- LTN-UC-2C-1
- LTN-UC-4C-1
- LTN-UC-6C-1
- LTN-UC-8C-1
- LTN-UC-10C-1
- LTN-UC-13C-1
- LTN-UC-16C-1
- LTN-UC-20C-1
- LTN-UC-25C-1
- LTN-UC-32C-1
- LTN-UC-40C-1
- LTN-UC-50C-1
- LTN-UC-63C-1

- LTN-UC-1C-2
- LTN-UC-2C-2
- LTN-UC-4C-2
- LTN-UC-6C-2
- LTN-UC-8C-2
- LTN-UC-10C-2
- LTN-UC-13C-2
- LTN-UC-16C-2
- LTN-UC-20C-2
- LTN-UC-25C-2
- LTN-UC-32C-2
- LTN-UC-40C-2
- LTN-UC-50C-2
- LTN-UC-63C-2

Handwritten signature

