

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1150254

Product: Residual current circuit breakers

Type: OLE, OLI

Rating: AC 230 V, 50/60 Hz; In: 6, 8, 10, 13, 16, 20, 25, 32, 40 A;
Ires.: 0,01; 0,03; 0,1; 0,3 A; Icn: 4,5; 6; 10 kA; char. B, C

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 500290-01/01 of: 07.04.2015

A sample of the product was found to be in conformity with:
ČSN EN 61009-1 ed.3:13, ČSN EN 61009-2-1:97+A11:99

The validity of the certificate is limited to: 30.4.2018

15.4.2015

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



500290-01