

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1150573

**Product:** Motor actuating system

**Type:** MP-BD-X110, MP-BD-X230, MP-BD-X110P, MP-BD-X230P

**Rating:** 220 V DC, 230 V AC, 50 Hz, 0,4 A

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 501426-01/01 of 29.07.2015

A sample of the product was found to be in conformity with:  
ČSN EN 60947-1 ed. 4:08+A1:11 cl. 7.2.1.2, 7.2.3.1, 8.3.3.7.1, 5.2, 7.1.2.2,  
ČSN EN 60947-2 ed. 3:07+1:07+A1:10+A2:13 cl. 7.2.1.1.5, 8.3.3.3

The validity of the certificate is limited to: 31.08.2018

24.08.2015

Prague

Sedláček Miroslav  
Head of Certification Body



Stamp



501426-01