

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1150737

**Product:** Circuit-breakers

**Type:** BD250NE405, BD250NE406, BD250SE405, BD250SE406,  
BH630NE405, BH630NE406, BH630SE405, BH630SE406

**Rating:** AC 690 V, 250 A (BD250), 630 A (BH630), 4 poles

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 503184-01/01 of: 21.10.2015

**A sample of the product was found to be in conformity with:**

ČSN EN 60947-1 ed.4:08 +A1:11+A2:15 čl. 8.3.3.3.4 and  
ČSN EN 60947-2 ed.3:07+1:07+A1:10+A2:13  
čl. 8.3.2.5, 8.3.3, 8.3.4, 8.3.5, 8.3.2.6.4, 8.3.6, annexe C,  
C2, C3, C4, annexe F, F4, F4.1, F4.1.3, F4.2, F4.3,  
F4.4, F4.5, F4.6, F4.7, F5, F5.1, F5.2, F5.3, F5.4, F6,  
F7, F8, F9, annexe G, annexe H, H2, H3, H4

**Other data:**

The validity of the certificate is limited to: 31.10.2018

02.11.2015

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



503184-01