

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1150738

Product: Circuit breakers

Type: BL 1000 SE305, BL 1600SE305

Rating: $U_e = 690$ V AC; $I_u =$ from 315 to 1000 A (BL 1000); $I_u =$ from 630 to 1600 A (BL1600), $I_{cu} = 65$ kA

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 503185-01/01 zof: 21.10.2015

A sample of the product was found to be in conformity with:
ČSN EN 60947-2 ed. 3:07+1:07+A1:10+A2:13, ČSN EN 60947-1 ed.4:08+A1:11+A2:15

Other data:

The validity of the certificate is limited to: 31.10.2018

02.11.2015

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



503185-01