

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160080

Product: Fuse-base

Type: S3PB00, S3PB1, S3PB2

Rating: Un = 690 V AC, 160 A, 250 A, 400 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 504872-01/01 of: 27.01.2016

A sample of the product was found to be in conformity with:
ČSN 35 4701-2 ed. 3:14, ČSN EN 60269-1 ed. 3:08+A1:10+A2:15

Other data:

The validity of the certificate is limited to: 31.01.2019

03.02.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



504872-01