

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160081

Product: Fuseholder

Type: OPVF10-1, OPVF10-2

Rating: 1000 V DC, 30 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: Wöhner GmbH & Co. KG
Mönchorödener Strasse 10, D-96472 Rödental, Germany

Trade mark:

The test results are stated in the test-report No.: 504040-01/01 of: 26.01.2016

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed. 3:08+A1:10+A2:15, ČSN 35 4701-2 ed. 3:14

Other data:

The validity of the certificate is limited to: 31.01.2019

03.02.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



504040-01