

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160200

Product: Fuse-links for protection of semiconductor devices

Type: P50V16

Rating: Un 1100 V=; 1800 (1500) V~; In 63 / 630 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 600364-01/01 of: 10.03.2016

A sample of the product was found to be in conformity with:
ČSN EN 60269-4 ed. 3:10+A1:13

Other data:

The validity of the certificate is limited to: 31.03.2019

22.03.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



600364-01