

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160283

Product: Switch-disconnectors

Type: BC160NT305-160-V, BC160NT405-160-V,
BD250NE305-250-V, BD250NE405-250-V,
BH630NE305-630-V, BH630NE405-630-V,
BL1000SE305-1000-V, BL1600SE305-1600-V

Rating: 690 V AC; 160, 250, 630, 1000, 1600 A, 50/60 Hz, $U_i=690$ V

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 600907-01/01 of: 01.04.2016

A sample of the product was found to be in conformity with:
ČSN EN 60947-3 ed.3:10+A1:12, ČSN EN 60947-1 ed.4:08+A1:11+A2:15

Other data:

The validity of the certificate is limited to: 30.04.2019

13.04.2016

Prague

RNDr. Milan Press
Deputy Head of Certification Body



Stamp



600907-01