

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160454

Product: Fuse-disconnector

Type: FH 000-1, FH 000-3, -1S, -3S

Rating: 160 A, 690 V AC

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 602263-01/01 of: 31.05.2016

A sample of the product was found to be in conformity with:
ČSN EN 60947-3 ed. 3:10+A1:12+A2:16
ČSN EN 60947-1 ed. 4:08+A1:11+A2:15

Other data:

The validity of the certificate is limited to: 30.06.2019

02.06.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



602263-01