

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1160469

**Product:** Empty enclosure for switchgear assemblies

**Type:** QA 40, QA 55

**Rating:** IK 10, IP 40 (QA 40), IP 55 (QA 55)

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 303325-01/01 of 30.07.2013


A sample of the product was found to be in conformity with:  
ČSN EN 62208 ed.2:12

**Other data:**

The validity of the certificate is limited to: 31.05.2019

07.06.2016

Prague

  
Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



602266-01