

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1160726

**Product:** Surge protective devices

**Type:** SJB..., SJBC..., SVC..., SVBC...,

**Rating:** Iimp 25 kA, 12,5 kA; In 25 kA, 12,5 kA

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 505035-01/01 of: 05.09.2016

A sample of the product was found to be in conformity with:  
ČSN EN 61643-11 ed. 2:13

**Other data:**

The validity of the certificate is limited to: 30.09.2019

23.09.2016

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



505035-01