

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160817

Product: Empty enclosure for switchgear assemblies

Type: DistriSet – DZ, DN, DZ...EI30 and accessories

Rating: do 1000 V, IP 43, IP 54

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 602264-01/01 of: 17.10.2016

A sample of the product was found to be in conformity with:
ČSN EN 62208 ed. 2:12

Other data:

The validity of the certificate is limited to: 31.10.2019

07.11.2016 corrigendum 04.01.2017

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



602264-01