

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160818

Product: Fuse-base

Type: SPB00

Rating: 690 V AC, 160 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 604473-01/01 of: 31.10.2016

A sample of the product was found to be in conformity with:

ČSN EN 60269-1 ed. 3:08+A1:10+A2:15 cl. 8.2, 8.3, 8.11, 8.5, 8.9, 8.11.2.2, 8.8, 8.11.2.1, ČSN 35 4701-2 ed. 3:14 cl. 8.1.4, 8.11.2.4

Other data:

The validity of the certificate is limited to: 30.11.2019

07.11.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



604473-01