

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1170023

Product: Fuse-base

Type: SPB1, SPB2, SPB2L

Rating: 690 V AC, 250 A (SPB1), 400 A (SPB2)

Ordering firm: OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 605264-01/01 of: 03.01.2017

A sample of the product was found to be in conformity with:  
ČSN EN 60269-1 ed.3:08+A1:10+A2:15 cl. 8.2, 8.3, 8.11.2.2;  
ČSN 35 4701-2 ed.3:14 cl. 8.1.4, 8.3, 8.11.2.4

Other data:

The validity of the certificate is limited to: 31.01.2020

13.01.2017

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



605264-01