

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1170182

Product: Neutral terminal bridges

Type: SNB00, SNF00, SNF1, SNF2

Rating: 690 V AC; 160 A (SNB00, SNF00); 250 A (SNF1); 400 A (SNF2)

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 700285-01/01 of: 28.02.2017

A sample of the product was found to be in conformity with:
ČSN 354701-2 ed.3:14 čl. 8.3, 8.11
IEC 60269-2:13 čl. 8.3, 8.11

Other data:

The validity of the certificate is limited to: 31.03.2020

09.03.2017

Prague


Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



700285-01