
FUSE-RAILS SIZE 1 UP TO 250 A, 2 UP TO 400 A, 3 UP TO 630 A





- the requirements for safe disconnection.
- Mounting width 100 mm.
- Safe fuse-link handling (in inserting the fuse-link first leans against insulating covers).
- Possibility of additional rebuild of the fuse-rail into a fuse switch-disconnector by simple addition of the superstructure. NL-FD.../3. without dismantling from
- Possibility of addition of measuring adapters with current transformers see page F13.
- FR1 connection to busbars by screws M10/20 Nm, FR2 and FR3 M12/28 Nm. Connection for cable lugs max. Ø 40 mm and busbars of width max. 30 mm.
- The fuse switch-disconnectors of vertical design of busbar systems (contact version LL) do not extend mounting width 100 mm, and are differentiated by grey contact covers.
- They enable mounting and check of connections without dismounting of adjacent devices, and without removing the contact cover.

Standard equipment:

- Contact covers.
- Interpole barriers.
- Outlet description label.

Fuse-rails

Туре	Product code	I _n [A]	Outlet terminals	Busbar spacing [mm]	Weight [kg]	Package [pcs]
FR1-3K/LM	11211		pressed-in nuts with screws M10		3.620	1
FR1-3K/LW	11212	250	V-shaped terminals for clamp 5845*	185	3.520	1
FR1-3K/LL	11213		switch-disconnector of busbar systems		2.740	1
FR2-3K/LM	11214		pressed-in nuts with screws M12		3.630	1
FR2-3K/LW	11215	400	V-shaped terminals for clamp 5845*	185	3.530	1
FR2-3K/LL	11216		switch-disconnector of busbar systems		2.750	1
FR3-3K/LM	11217		pressed-in nuts with screws M12		4.060	1
FR3-3K/LW	11218	630	V-shaped terminals for clamp 5845*	185	4.140	1
FR3-3K/LL	11219		switch-disconnector of busbar systems		2.840	1

Fuse-rails FR. are suitable for application in disconnecting cabinets or low-voltage distribution switchboards with busbar spacing 185 mm.

Accessories

Description	Туре	Product code	Weight [kg]	Package [pcs]
Connecting space cover transparent, used for covering of the outlet connection space	KPT-F123	40854	0.145	1
Free place cover, intended for covering of the switchboard free place between two fuse-rails, width 100 mm	KM-F123	11277	0.230	1
Free place cover clips, for attachment of the free place cover KM-F123 to switch-disconnector (set of 4 pcs)	CM-F123	11278	0.006	1
Switch-disconnector superstructure, it enables rebuild of the fuse-rail FR1 and FR2 into a fuse switch-disconnector FD1 and FD2 (1-pole control)	NL-FD12/31	11270	2.100	1
Switch-disconnector superstructure, it enables rebuild of the fuse-rail FR1 and FR2 into a fuse switch-disconnector FD1 and FD2 (3-pole control)	NL-FD12/33	11271	2.300	1
Switch-disconnector superstructure, it enables rebuild of the fuse-rail FR3 into a fuse switch-disconnector FD3 (1-pole control)	NL-FD3/31	39325	2.100	1
Switch-disconnector superstructure, it enables direct connection by two Cu or Al conductors up to 240 mm² without cable lugs by means of clamps (the shaped clamps must be ordered separately)	NL-FD3/33	39326	2.300	1
Connecting set, It enables direct connection by two parallel Cu or Al conductors up to 240 mm ² without cable lugs by means of clamps (the shaped clamps must be ordered separately)	WD-FD	14901	0.720	1

Specifications


Туре		FR1	FR2	FR3
Rated current	ľ	250 A	400 A	630 A
Rated voltage (a.c./d.c.)	Ü		690 V	
Rated thermal current with disconnecting link ZP/cross-section	I _{th}	400 A/240 mm ²	560 A/2x 185 mm ²	800 A/2x 185 mm ²
Rated frequency	f		40 ÷ 60 Hz	
Rated insulation voltage	Ü		1000 V a.c.	
Fuse-link size		1	2	3
Max. power losses of the fuse-link	P _v	32 W	45 W	60 W
Degree of protection			IP 20	
Operating ambient temperature			-25 ÷ +55 °C	
Standards			IEC 60269-1, -2	
Approval marks			@ C E	



The shaped clamps must be ordered separately see page D27.

Varius

FUSE-RAILS SIZE 1 UP TO 250 A, 2 UP TO 400 A, 3 UP TO 630 A



MINIMAL CONNECTING CROSS-SECTION OF FUSE SWITCH-DISCONNECTORS

Minimal connecting cross-section of cables of fuse switch-disconnectors for cylindrical fuse-links

Fuse-links		witch-discor ylindrical fus	Cable S [mm²]		
I _n [A]	OPVA10 OPVA14		OPVA22	Cu	AI
0.25	х	х		1	-
0.5	Х	Х		1	-
1	Х	Х		1	-
2	Х	х		1	-
4	Х	х		1	-
6	Х	Х		1	-
8	Х	х		1	-
10	Х	Х		1.5	-
12	Х	х		1.5	-
16	Х	х	Х	2.5	-
20	Х	х	Х	2.5	-
25	Х	Х	Х	4	-
32	Х	х	Х	4	-
40		х	Х	10	-
50		Х	Х	10	16
63		Х	Х	16	25
80			Х	25	35
100			Х	35	50
125			X	50	70

Notes:

Minimal connecting cross-section of cables and busbars of fuse switch-disconnectors and fuse rails

Fuse-links		Fuse switch-disconnectors and fuse-rails								Cable Busbar			bar
I _n [A]	FULLER	FILOS	FH00 FH1	FH2	FIID	FD00	FD1	FD2	FD3	S [mm²]		w x h	
	FH000	rnuu			FH3	FR00	FR1	FR2	FR3	Cu	Al	Cu	Al
4	Х	Х				Х				1	-	-	-
6	Х	Х	Х			Х	Х			1	-	-	-
8	Х	х	х			Х	х			1	-	-	-
10	Х	х	х			Х	Х			1.5	-	-	-
12	Х	х	х			Х	х			1.5	-	-	-
16	Х	х	х			Х	Х			2.5	-	-	-
20	Х	х	х			Х	х			2.5	-	-	-
25	Х	Х	Х			Х	Х			4	-	-	-
32	Х	х	х	х		х	х	х		4	-	-	-
35	Х	х	х	Х		Х	х	Х		6	-	-	-
40	Х	х	х	Х		Х	х	х		10	-	-	-
50	Х	Х	Х	Х		Х	Х	Х		10	16	-	-
63	Х	х	х	х		х	х	х		16	25	-	-
80	Х	х	х	Х	Х	Х	Х	Х	х	25	35	-	-
100	Х	х	х	Х	Х	Х	х	х	х	35	50	20 x 2	25 x 2
125	Х	Х	Х	Х	Х	Х	Х	Х	Х	50	70	25 x 2	25 x 3
160	Х	х	х	х	х	х	х	х	х	70	95	25 x 3	25 x 4
200			х	Х	Х		Х	х	х	95	120	25 x 4	25 x 5
224			х	Х	Х		х	х	х	95	120	25 x 4	25 x 5
250			Х	Х	Х		Х	Х	Х	120	150	25 x 5	25 x 6
315				х	х			х	х	150	185	32 x 5	32 x 6
350				Х	Х			х	х	185	240	32 x 6	32 x 8
400				х	х			х	х	240	2x 150	32 x 8	40 x 8
500					Х				х	2x 150	2x 185	2x 30 x 5	2x 40 x 5
630					х				х	2x 185	2x 240	2x 40 x 5	2x 40 x 8

Notes

¹⁾ Applies to ambient temperature of swich-disconnectors max. 40 $^{\circ}\text{C}$

²⁾ Applies to HRC fuse-links PVA10, PV10, PV14, PV22

¹⁾ Applies to ambient temperature of swich-disconnectors max. 40 $^{\circ}\text{C}$

²⁾ Applies to HRC fuse-links PNA, PHNA