

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1070296

**Product:** Switch

**Type:** AST

**Rating:** 125 A, 230/400 V AC, AC 22 A

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 700810-01/01 of: 10.04.2007

A sample of the product was found to be in conformity with:  
ČSN EN 60947-3:00 ed.2+A1:02+A2:06 cl. 5.2, 8.2, 8.3.3, 8.3.4, 8.3.6, 8.3.7  
ČSN EN 60947-1:05 ed.3 cl. 7.1.1, 7.1.1.1

The validity of the certificate is limited to: 30.4.2010

17.4.2007

Prague

Pavel Kudrna  
Certification and Inspection Manager



Stamp



700810-01