

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1210475

Product: Residual current circuit breakers

Type: OLE, OLI (see Annex)

Rating: AC 230 V, 50/60 Hz; I_n : 6, 10, 16, 20, 25, 32, 40 A; I_{res} : 0,03; 0,3 A; I_{cn} : 6; 10 kA; char. B, C

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 211887-01/01 of: 10.08.2021

A sample of the product was found to be in conformity with:
ČSN EN 61009-1 ed.3:13+A1:15+A2:15+A11:16+A12:17, ČSN EN 61009-2-1:97+A11:99

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 211887 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 23.08.2024

24.08.2021 Corrigendum 13.09.2021

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



211887-01

OLI,OLE

Type marking	Type marking	Type marking	Type marking
10kA, AC	10kA, A	10kA, AC-G	6kA, AC
OLI-6B-1N-030AC	OLI-16B-1N-030A	OLI-10B-1N-030AC-G	OLE-6B-1N-030AC
OLI-10B-1N-030AC	OLI-10B-1N-030A	OLI-16B-1N-030AC-G	OLE-10B-1N-030AC
OLI-16B-1N-030AC	OLI-16B-1N-030A	OLI-20B-1N-030AC-G	OLE-16B-1N-030AC
OLI-20B-1N-030AC	OLI-20B-1N-030A	OLI-25B-1N-030AC-G	OLE-20B-1N-030AC
OLI-25B-1N-030AC	OLI-25B-1N-030A	OLI-10C-1N-030AC-G	OLE-25B-1N-030AC
OLI-32B-1N-030AC	OLI-32B-1N-030A	OLI-16C-1N-030AC-G	OLE-32B-1N-030AC
OLI-40B-1N-030AC	OLI-40B-1N-030A	OLI-20C-1N-030AC-G	OLE-40B-1N-030AC
OLI-6C-1N-030AC	OLI-6C-1N-030A	OLI-25C-1N-030AC-G	OLE-6C-1N-030AC
OLI-10C-1N-030AC	OLI-10C-1N-030A		OLE-10C-1N-030AC
OLI-16C-1N-030AC	OLI-16C-1N-030A		OLE-16C-1N-030AC
OLI-20C-1N-030AC	OLI-20C-1N-030A		OLE-20C-1N-030AC
OLI-25C-1N-030AC	OLI-25C-1N-030A		OLE-25C-1N-030AC
OLI-32C-1N-030AC	OLI-32C-1N-030A		OLE-32C-1N-030AC
OLI-40C-1N-030AC	OLI-40C-1N-030A		OLE-40C-1N-030AC
OLI-6C-1N-300AC	OLI-6C-1N-300A		
OLI-10C-1N-300AC	OLI-10C-1N-300A		
OLI-16C-1N-300AC	OLI-16C-1N-300A		
OLI-20C-1N-300AC	OLI-20C-1N-300A		
OLI-25C-1N-300AC	OLI-25C-1N-300A		
OLI-32C-1N-300AC	OLI-32C-1N-300A		
OLI-40C-1N-300AC	OLI-40C-1N-300A		

Type marking
10kA, F
OLI-6B-1N-030F-K
OLI-10B-1N-030F-K
OLI-13B-1N-030F-K
OLI-16B-1N-030F-K
OLI-20B-1N-030F-K
OLI-25B-1N-030F-K
OLI-32B-1N-030F-K
OLI-40B-1N-030F-K
OLI-6C-1N-030F-K
OLI-10C-1N-030F-K
OLI-13C-1N-030F-K
OLI-16C-1N-030F-K
OLI-20C-1N-030F-K
OLI-25C-1N-030F-K
OLI-32C-1N-030F-K
OLI-40C-1N-030F-K

