

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220257

Product: Fuse holder

Type: SP40T06, SP41T06

Rating: $I_n = 160, 250, 400 \text{ A}$, $U_n = 690 \text{ V AC}$

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 220874-01/01 of: 13.05.2022

A sample of the product was found to be in conformity with:
ČSN 35 4701-2 ed.3:14 (mod. IEC 60269-2:13) cl. 8.11.1.2

Other data:

The validity of the certificate is limited to: 22.05.2025

23.05.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



220874-01