

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod liseň 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220508

Product: Empty enclosure for switchgear assemblies

Type: QA 40, QA 55

Rating: IK10, IP40 (QA 40), IP55 (QA 55)

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 222301-01/01 of: 24.10.2022

A sample of the product was found to be in conformity with:
ČSN EN 62208 ed.2:12

Other data:

The validity of the certificate is limited to: 30.10.2025

31.10.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



222301-01