

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1230033

**Product:** Circuit breaker

**Type:** LMB (see Enclosure)

**Rating:** AC 230 V, 2 A - 40 A (see Enclosure)

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 222469-01/01 of: 02.02.2023

**A sample of the product was found to be in conformity with:**  
ČSN EN 60898-1 ed.2:19

**Other data:**

**The validity of the certificate is limited to:** 06.02.2026

07.02.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



222469-01

**Rated current ( $I_n$ )**                      **Type marking****Characteristic B**

6 A	LMB-6B-1N
10 A	LMB-10B-1N
13 A	LMB-13B-1N
16 A	LMB-16B-1N
20 A	LMB-20B-1N
25 A	LMB-25B-1N
32 A	LMB-32B-1N
40 A	LMB-40B-1N

**Characteristic C**

2 A	LMB-2C-1N
4 A	LMB-4C-1N
6 A	LMB-6C-1N
8 A	LMB-8C-1N
10 A	LMB-10C-1N
13 A	LMB-13C-1N
16 A	LMB-16C-1N
20 A	LMB-20C-1N
25 A	LMB-25C-1N
32 A	LMB-32C-1N
40 A	LMB-40C-1N

