

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230061

Product: Steelplastic distribution board

Type: DBO - RZA (variants see Annex)

Rating: 3x400/230 V, do 63 A, 50 Hz, IP 30/20

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 230379-01/01 of: 27.02.2023

A sample of the product was found to be in conformity with:

ČSN EN 61439-3:12+1:19,

ČSN EN 61439-1 ed. 2:12+1:15+Z2:22,

cl. 5, 6, 10.2, 10.3, 10.4, 10.9.2, 10.9.4, 10.10.4, 10.11.2, 10.12 (J.9.4.3.1, J.9.4.4.1), 10.13

Other data:

The validity of the certificate is limited to: 06.03.2026

07.03.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



230379-01

Type marking of distribution boards

