

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230097

Product: Cylindrical fuse-links

Type: PV 10, PV 14, PV 22 aM,gG

Rating: 0,25 - 125 A, 690/500/400 V AC, 250 V DC, aM;
2 - 125 A, 690/500 V AC, 250 V DC, gG

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 230634-01/01 of: 21.03.2023

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed.3:08+A1:10+A2:15, ČSN 35 4701-2 ed.3:14

Other data:

The validity of the certificate is limited to: 27.03.2026

28.03.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



230634-01