

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1230098

**Product:** Neutral terminal bridges

**Type:** SNB00, SNF1, SNF2

**Rating:** 690 V AC, 160 A (SNB00), 250 A (SNF1), 400 A (SNF2)

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 230633-01/01 of: 21.03.2023

**A sample of the product was found to be in conformity with:**  
ČSN 35 4701-2 ed.3:14 cl. 8.3, 8.11

**Other data:**

**The validity of the certificate is limited to:** 27.03.2026

28.03.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



230633-01