

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230345

Product: Fuse-base, Neutral terminal bridge

Type: SPF 00, 1, 2, 3, SNF 00, 1, 2

Rating: 690 V AC, 160, 250, 400, 630 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 231666-01/01 of: 31.07.2023

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed. 3:08+A1:10+A2:15

Other data:

The validity of the certificate is limited to: 06.08.2026

07.08.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



231666-01