

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod litem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1230346

**Product:** Cylindrical fuse for photovoltaic energy systems

**Type:** PC10gPV

**Rating:**  $U_n$  1000 V DC,  $I_n$  2, 4, 6, 8, 10, 12, 16, 20 A

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 231667-01/01 of: 31.07.2023

**A sample of the product was found to be in conformity with:**  
ČSN EN 60269-6:11, ČSN EN 60269-1 ed. 3:08+A1:10+A2:15, ČSN 35 4701-2 ed. 3:14+Z1:23

**Other data:**

**The validity of the certificate is limited to:** 06.08.2026

07.08.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



231667-01